



Model Number

NJ1,5-8GM-N

Features

- 1.5 mm flush
- Usable up to SIL 2 acc. to IEC 61508

Accessories

BF 8

Mounting flange, 8 mm

Technical Data

General specifications

Switching function		Normally closed (NC)
Output type		NAMUR
Rated operating distance	s_n	1.5 mm
Installation		flush
Assured operating distance	s_a	0 ... 1.215 mm
Actual operating distance	s_r	1.35 ... 1.65 mm typ.
Reduction factor r_{AI}		0.4
Reduction factor r_{CU}		0.3
Reduction factor r_{304}		0.85
Output type		2-wire

Nominal ratings

Nominal voltage	U_o	8.2 V (R_i approx. 1 k Ω)
Switching frequency	f	0 ... 5000 Hz
Hysteresis	H	1 ... 10 typ. 5 %
Suitable for 2:1 technology		yes, Reverse polarity protection diode not required
Current consumption		
Measuring plate not detected		≥ 3 mA
Measuring plate detected		≤ 1 mA

Functional safety related parameters

Safety Integrity Level (SIL)	SIL 2
------------------------------	-------

Ambient conditions

Ambient temperature	-25 ... 100 °C (-13 ... 212 °F)
---------------------	---------------------------------

Mechanical specifications

Connection type	cable PVC, 2 m
Core cross-section	0.14 mm ²
Housing material	Stainless steel 1.4305 / AISI 303
Sensing face	PBT
Degree of protection	IP66 / IP67
Cable	
Cable diameter	2.6 mm $\pm$ 0.2 mm
Bending radius	> 10 x cable diameter

General information

Use in the hazardous area	see instruction manuals
---------------------------	-------------------------


Compliance with standards and directives

Standard conformity	
NAMUR	EN 60947-5-6:2000 IEC 60947-5-6:1999
Standards	EN 60947-5-2:2007 EN 60947-5-2/A1:2012 IEC 60947-5-2:2007 IEC 60947-5-2 AMD 1:2012

Approvals and certificates


EAC conformity	TR CU 012/2011
FM approval	
Control drawing	116-0165
UL approval	
Ordinary Location	E87056
Hazardous Location	E501628
Control drawing	116-0452
CSA approval	cCSAus Listed, General Purpose
CCC approval	CCC approval / marking not required for products rated ≤ 36 V

Dimensions





Electrical Connection



Data for application in connection with hazardous areas

Equipment protection level	Ga , Gb , Da , Mb
----------------------------	-------------------

Equipment protection level Ga

Type of protection	intrinsic safety
CE marking	CE 0102

Certificates

Appropriate type	NJ1,5-8GM-N...
ATEX certificate	PTB 00 ATEX 2048 X
ATEX marking	Ex II 1G Ex ia IIC T6...T1 Ga
Standards	EN 60079-0:2012 +A11:2013, EN 60079-11:2012
IECEx certificate	IECEx PTB 11.0037X
IECEx marking	Ex ia IIC T6...T1 Ga
Standards	IEC 60079-0:2011 , IEC 60079-11:2011

Effective internal capacitance	C_i	$\leq 30 \text{ nF}$ A cable length of 10 m is considered.
--------------------------------	-------	---

Effective internal inductance	L_i	$\leq 50 \text{ }\mu\text{H}$ A cable length of 10 m is considered.
-------------------------------	-------	--

Maximum permissible ambient temperature T_{amb}	Also observe the maximum permissible ambient temperature stated in the general technical data. Keep to the lower of the two values.
---	--

for ATEX

at $U_i = 16 \text{ V}$, $I_i = 25 \text{ mA}$, $P_i = 34 \text{ mW}$,
 T6 : 56 °C (132.8 °F)
 T5 : 68 °C (154.4 °F)
 T4 : 96 °C (204.8 °F)
 T3 : 96 °C (204.8 °F)
 T2 : 96 °C (204.8 °F)
 T1 : 96 °C (204.8 °F)
 at $U_i = 16 \text{ V}$, $I_i = 25 \text{ mA}$, $P_i = 64 \text{ mW}$,
 T6 : 51 °C (123.8 °F)
 T5 : 63 °C (145.4 °F)
 T4 : 91 °C (195.8 °F)
 T3 : 91 °C (195.8 °F)
 T2 : 91 °C (195.8 °F)
 T1 : 91 °C (195.8 °F)
 at $U_i = 16 \text{ V}$, $I_i = 52 \text{ mA}$, $P_i = 169 \text{ mW}$,
 T6 : 32 °C (89.6 °F)
 T5 : 44 °C (111.2 °F)
 T4 : 67 °C (152.6 °F)
 T3 : 67 °C (152.6 °F)
 T2 : 67 °C (152.6 °F)
 T1 : 67 °C (152.6 °F)
 at $U_i = 16 \text{ V}$, $I_i = 76 \text{ mA}$, $P_i = 242 \text{ mW}$,
 T6 : 19 °C (66.2 °F)
 T5 : 31 °C (87.8 °F)
 T4 : 41 °C (105.8 °F)
 T3 : 41 °C (105.8 °F)
 T2 : 41 °C (105.8 °F)
 T1 : 41 °C (105.8 °F)

for IECEx

at $U_i = 16 \text{ V}$, $I_i = 25 \text{ mA}$, $P_i = 34 \text{ mW}$,
 T6 : 73 °C (163.4 °F)
 T5 : 88 °C (190.4 °F)
 T4 : 100 °C (212 °F)
 T3 : 100 °C (212 °F)
 T2 : 100 °C (212 °F)
 T1 : 100 °C (212 °F)
 at $U_i = 16 \text{ V}$, $I_i = 25 \text{ mA}$, $P_i = 64 \text{ mW}$,
 T6 : 68 °C (154.4 °F)
 T5 : 83 °C (181.4 °F)
 T4 : 100 °C (212 °F)
 T3 : 100 °C (212 °F)
 T2 : 100 °C (212 °F)
 T1 : 100 °C (212 °F)
 at $U_i = 16 \text{ V}$, $I_i = 52 \text{ mA}$, $P_i = 169 \text{ mW}$,
 T6 : 49 °C (120.2 °F)
 T5 : 64 °C (147.2 °F)
 T4 : 67 °C (152.6 °F)
 T3 : 67 °C (152.6 °F)
 T2 : 67 °C (152.6 °F)
 T1 : 67 °C (152.6 °F)
 at $U_i = 16 \text{ V}$, $I_i = 76 \text{ mA}$, $P_i = 242 \text{ mW}$,
 T6 : 36 °C (96.8 °F)
 T5 : 42 °C (107.6 °F)
 T4 : 42 °C (107.6 °F)
 T3 : 42 °C (107.6 °F)
 T2 : 42 °C (107.6 °F)
 T1 : 42 °C (107.6 °F)

Equipment protection level Gb

Type of protection		intrinsic safety
CE marking		CE 0102
Certificates		
Appropriate type		NJ1,5-8GM-N...
ATEX certificate		PTB 00 ATEX 2048 X
ATEX marking		II 1G Ex ia IIC T6...T1 Ga
Standards		EN 60079-0:2012+A11:2013 , EN 60079-11:2012
IECEX certificate		IECEX PTB 11.0037X
IECEX marking		Ex ia IIC T6...T1 Ga
Standards		IEC 60079-0:2011 , IEC 60079-11:2011
Effective internal capacitance	C _i	≤ 30 nF A cable length of 10 m is considered.
Effective internal inductance	L _i	≤ 50 μH A cable length of 10 m is considered.
Maximum permissible ambient temperature T _{amb}		Also observe the maximum permissible ambient temperature stated in the general technical data. Keep to the lower of the two values. at U _i = 16 V , I _i = 25 mA , P _i = 34 mW , T ₆ : 73 °C (163.4 °F) T ₅ : 88 °C (190.4 °F) T ₄ : 100 °C (212 °F) T ₃ : 100 °C (212 °F) T ₂ : 100 °C (212 °F) T ₁ : 100 °C (212 °F) at U _i = 16 V , I _i = 25 mA , P _i = 64 mW , T ₆ : 68 °C (154.4 °F) T ₅ : 83 °C (181.4 °F) T ₄ : 100 °C (212 °F) T ₃ : 100 °C (212 °F) T ₂ : 100 °C (212 °F) T ₁ : 100 °C (212 °F) at U _i = 16 V , I _i = 52 mA , P _i = 169 mW , T ₆ : 49 °C (120.2 °F) T ₅ : 64 °C (147.2 °F) T ₄ : 67 °C (152.6 °F) T ₃ : 67 °C (152.6 °F) T ₂ : 67 °C (152.6 °F) T ₁ : 67 °C (152.6 °F) at U _i = 16 V , I _i = 76 mA , P _i = 242 mW , T ₆ : 36 °C (96.8 °F) T ₅ : 42 °C (107.6 °F) T ₄ : 42 °C (107.6 °F) T ₃ : 42 °C (107.6 °F) T ₂ : 42 °C (107.6 °F) T ₁ : 42 °C (107.6 °F)

Equipment protection level Da

Type of protection		intrinsic safety	
CE marking		C E 0102	
Certificates			
Appropriate type		NJ1,5-8GM-N...	
ATEX certificate		PTB 00 ATEX 2048 X	
ATEX marking		II 1D Ex ia IIIC T135°C Da	
Standards		EN 60079-0:2012+A11:2013 , EN 60079-11:2012	
IECEX certificate		IECEX PTB 11.0037X	
IECEX marking		Ex ia IIIC T135°C Da	
Standards		IEC 60079-0:2011 , IEC 60079-11:2011	
Effective internal capacitance	C _i	≤ 30 μF A cable length of 10 m is considered.	
Effective internal inductance	L _i	≤ 50 μH A cable length of 10 m is considered.	
Maximum permissible ambient temperature T _{amb}		Also observe the maximum permissible ambient temperature stated in the general technical data. Keep to the lower of the two values. at U _i = 16 V , I _i = 25 mA , P _i = 34 mW : 100 °C (212 °F) at U _i = 16 V , I _i = 25 mA , P _i = 64 mW : 100 °C (212 °F) at U _i = 16 V , I _i = 52 mA , P _i = 169 mW : 67 °C (152.6 °F) at U _i = 16 V , I _i = 76 mA , P _i = 242 mW : 41 °C (105.8 °F)	

Equipment protection level Mb

Type of protection		intrinsic safety
Certificates		
Appropriate type		NJ1,5-8GM-N...
IECEx certificate		IECEx PTB 11.0037X
IECEx marking		Ex ia I Mb
Standards		IEC 60079-0:2011 , IEC 60079-11:2011
Effective internal capacitance	C _i	≤ 30 nF A cable length of 10 m is considered.
Effective internal inductance	L _i	≤ 50 μH A cable length of 10 m is considered.

Release date: 2019-08-05 14:13 Date of issue: 2019-08-05 106361_eng.xml



Maximum permissible ambient temperature T_{amb}

Also observe the maximum permissible ambient temperature stated in the general technical data.
Keep to the lower of the two values.
at $U_i = 16\text{ V}$, $I_i = 25\text{ mA}$, $P_i = 34\text{ mW}$: 100 °C (212 °F)
at $U_i = 16\text{ V}$, $I_i = 25\text{ mA}$, $P_i = 64\text{ mW}$: 100 °C (212 °F)
at $U_i = 16\text{ V}$, $I_i = 52\text{ mA}$, $P_i = 169\text{ mW}$: 67 °C (152.6 °F)
at $U_i = 16\text{ V}$, $I_i = 76\text{ mA}$, $P_i = 242\text{ mW}$: 41 °C (105.8 °F)

Release date: 2019-08-05 14:13 Date of issue: 2019-08-05 106361_eng.xml